



APPROVER!
STAIR WIDTHS NEED TO BE 3'-10" IN ORDER TO CLEAR OPENINGS.
VERIFY ALL ELEVATIONS & CONNECTIONS OF STAIRS TO COLUMNS
& TO TOWER STEEL SUPPORTS AS SHN ON E13-E18.
PLEASE REVIEW AND VERIFY ALL CLOUDED AREAS.

APPROVER!
ALL DIMENSIONS AND INFORMATION NEEDS TO BE VERIFIED.
ARCH & STRUCT CONFLICT IN LOCATION OF THE ELEVATOR.
PLEASE REVIEW AND VERIFY ALL CLOUDED AREAS.

APPROVER!
IT APPEARS THE STAIRS MAY BE AFFECTED BY OTHER TRADES.
PLEASE REVIEW & VERIFY THAT PROPER CLEARANCES HAVE BEEN
PROVIDED TO ALLOW FOR PERFORATED METAL PANELS & LED LIGHTING
UNDER STRINGERS. REF 2/A601.

STAIR MATERIAL NOTES:

- 1) ALL STRINGERS ARE C12x20.7
- 2) ALL LANDING FRAMES ARE C12x20.7.
- 3) ALL LANDING SUPPORTS ARE C6x8.2.
- 4) ALL PANS ARE 12 GA.
- 5) ALL PAN SUPPORTS AT LANDINGS ARE L3x3x1/4.
- 6) ALL PAN SUPPORTS ON STRINGERS ARE L1 1/2x1 1/4x1/8.
- 6) ALL WELD PLATES ARE 3/8" THICK.

COLUMN MATERIAL NOTES:

- 1) ALL STAIR COLUMNS ARE HSS 3x3x1/4
- 2) BASE PLATES ARE PL3/4x9x0'-9 W/ 3/4" EXP BOLTS x 0'-8

RAIL MATERIAL NOTES:

- 1) POSTS ARE BAR 2"x3/8"
- 2) PICKETS ARE 1/2" SQ BAR
- 3) TOP RAIL IS 1 1/2" STD PIPE
- 4) GRAB RAIL IS 1 1/2" STD PIPE
- 5) POSTS ARE TO BE CENTERED ON STRINGERS & WELDED.
- 6) RAIL HEIGHT IS TO BE 3'-6" ABOVE FINISH FLOOR
- 7) GRAB RAIL HEIGHT IS TO BE 2'-10" ABOVE FINISH FLOOR.
- 8) WHEN A POST IS ON CONCRETE, THEN CORE DRILL.

FLOOR PLANS SHOWN ON E13-E15.
ALL SECTIONS SHOWN ON E16-E18.

STAIR TOWER PLAN @ SUITE LEVEL

This document and the information contained in it are the confidential property of LYD-STEEL and may not be copied, duplicated, used in any manner, or transmitted to others without the written consent of LYD-STEEL.

Holes 13/16"Ø U.N.
Bolts — U.N.
Welds — U.N.
Paint 1 S/C PRIMER

LYD-STEEL
Steel Detailing / Checking

6400 FAIR VALLEY TRAIL, AUSTIN, TEXAS 78749
PHONE: (512) 484-3197 EMAIL: LYD-STEEL@ATT.NET

PRINT RECORD

Date	NO.	For
-/-/-	-	-
-/-/-	-	-
-/-/-	-	-
-/-/-	-	-
-/-/-	-	-
-/-/-	-	-

Details of _____
Customer _____
Project DELL DIAMOND
Location ROUND ROCK, TEXAS
Architect _____

Drawn LTS
Checked _____

Date 12/07/09
Date _____

Job No. _____
Sample

Sheet No.
E14

SCALE : 1" = 1'-0"